

# EU Declaration of Conformity

# Texecom



Document Reference : DEC-T00222  
Notified Body : BSI  
0086-CPR-96704

Bradwood Court, St. Crispins Way  
Haslingden, Lancashire, BB4 4PW  
United Kingdom

Object of the declaration: Heat detectors

Part No.	Product Type	Description
AGB-0002	Exodus RR/4W	Class A1R Conventional 4 wire Rate of rise Heat Detector
AGB-0003	Exodus FT64/4W	Class A2 Conventional 4 wire Fixed Temperature Heat Detector
AGB-0004	Exodus FT90/4W	Class C Conventional 4 Wire High Temperature Heat Detector
AGA-0002	Exodus RR/2W	Class AR Conventional 2 wire Rate of Rise Heat Detector
AGA-0003	Exodus FT64/2W	Class C Conventional 2 Wire Fixed Temperature Heat Detector
AGA-0004	Exodus FT90/2W	Class C Conventional 2 Wire High Temperature Heat Detector
AGA-0010	Mounting Bases	Exodus Detector Mounting base

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

305/2011EU	Construction Products Regulation
2014/30/EU	EMC Directive
2011/65/EU	ROHS Directive

This is demonstrated by conformity against the following harmonised standards

Standard	Edition/ Date of Issue	Title of Standard
EN 61000-6-3	2007/A1:2011/AC:2012	Electromagnetic compatibility (EMC) — Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments
EN 50130-4	2011	Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems
EN 55022	2010	Emission Standard for Information Technology Equipment
EN 54-5	2001	Fire detection and fire alarm systems. Heat detectors. Point detectors

This declaration is issued under the sole responsibility of the manufacturer.

Hugh Devereux  
Head of Approval & Compliance

**RELEASED**



CERTIFICATE NUMBER: FM35285

