

Certificate of Product Approval

Certificate Number: 717e

Issue: 04



Texecom Ltd

Bradwood Court
St Crispin Way
Haslingden
Lancashire
BB4 4PW
United Kingdom

is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Visual Warning Devices

ESBA3000R
ESBA3000W
ESBA4000R
ESBA4000W
ESDA2000R
ESDA2000W
ESDA1000R
ESDA1000W

(Refer to Appendix for details)

Standards

EN 54-23:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan
Verifier

23 March 2017
Date of Issue

20 September 2013
Date of First Issue

Signed for BRE Global Ltd



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 717e

Issue: 04

Texecom Ltd

Certified Product	Description	LPCB Ref.No.
ESBA3000R	Conventional Type A/B ceiling mounted white light LED visual alarm device (red head / red bases) – (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following: – Category C-3-15 – Flash rates 0.5Hz and 1Hz – Synchronization	717e/01
ESBA3000W	Conventional Type A/B ceiling mounted white light LED visual alarm device (white head / white bases) – (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following: – Category C-3-15 – Flash rates 0.5Hz and 1Hz – Synchronization	717e/02
ESBA4000R	Conventional Type A/B wall mounted white light LED visual alarm device (red head / red bases) – (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: – Category W-3.1-11.3	717e/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

23 March 2017
Date of Issue

20 September 2013
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 717e

Issue: 04

Texecom Ltd

Certified Product	Description	LPCB Ref.No.
	<ul style="list-style-type: none"> - Flash rates 0.5Hz and 1Hz - Synchronization 	
ESBA4000W	Conventional Type A/B wall mounted white light LED visual alarm device (white head / white bases) – (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category W-3.1-11.3 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/04
ESDA2000R	Conventional Type A/B ceiling mounted red light LED visual alarm device (red head / red bases) – (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category C-3-8.9 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/05
ESDA2000W	Conventional Type A/B ceiling mounted red light LED visual alarm device (white head / white bases) – (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following:	717e/06

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

23 March 2017
Date of Issue

20 September 2013
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 717e

Issue: 04

Texecom Ltd

Certified Product	Description	LPCB Ref.No.
	<ul style="list-style-type: none"> - Category C-3-8.9 - Flash rates 0.5Hz and 1Hz - Synchronization 	
ESDA1000R	Conventional Type A/B wall mounted red light LED visual alarm device (red head / red bases) – (PSO-0001 / 18-185856-2, PSO-0017 / HSG6918 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category W-2.4-7.5 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/07
ESDA1000W	Conventional Type A/B wall mounted red light LED visual alarm device (white head / white bases) – (PSO-0006 / 18-186049-2, PSO-0018 / HSG6917 bases) Notes: 1. The VAD is Type A when used with the shallow base & Type B with the deep base. 2. The wall mounted VAD meets the requirements of EN 54-23:2010 for the following: <ul style="list-style-type: none"> - Category W-2.4-7.5 - Flash rates 0.5Hz and 1Hz - Synchronization 	717e/08

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

23 March 2017
Date of Issue

20 September 2013
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 717e

Issue: 04

Texecom Ltd

Bases

PSO-0001 / 18-185856-2	Red shallow base
PSO-0017 / HSG6918	Red deep base
PSO-0006 / 18-186049-2	White shallow base
PSO-0018 / HSG6917	White deep base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

23 March 2017
Date of Issue

20 September 2013
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 717e

Issue: 04

Texecom Ltd

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
717e/03	ESBA4000R	1000-300	Syncoln Ltd	717e-(cl-1)
717e/03	ESBA4000R	1000-301	Syncoln Ltd	717e-(cl-1)

Bases

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
717	PSO-0001	PSO-0001	Syncoln Ltd	717
717	PSO-0017	PSO-0017	Syncoln Ltd	717

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

23 March 2017
Date of Issue

20 September 2013
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.


